

TEXAS DEPARTMENT OF INSURANCE

Engineering Services Program / MC 103-3A 333 Guadalupe Street P.O. Box 149104 Austin, Texas 78714-9104
Phone No. (512) 322-2212 Fax No. (512) 463-6693

PRODUCT EVALUATION

DR-675

Effective Date: March 1, 2014

Reevaluation Date: **February 2018**

*The following product has been evaluated for compliance with the wind loads specified in the **International Residential Code (IRC)** and the **International Building Code (IBC)**.*

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

Premium Atlantic Vinyl (3400) Outswing French Patio Doors, Non-Impact Resistant, manufactured by

JELD-WEN Windows & Doors

3737 Lakeport Blvd.

Post Office Box 1329

Klamath Falls, Oregon 97601

Telephone: (541) 882-3451

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Premium Atlantic Vinyl (3400) Outswing French Patio Doors	Maximum Size Tested: 71.50" x 95.50"	+50 / -35 psf

Product Dimensions:

System	Overall Size	Panel Size	Daylight Opening Size
1	71.50" x 95.50"	Two: 34.13" x 93.06"	24.25" x 83.25"

Hardware:

- Hinges; Three required per door; Secured to the door panel with four No. 8 x 1" screws. Secured to the door jamb with two No. 10 x 1-1/2" screws and two No. 8 x 1" screws.
- 3-point locking system by Hoppe; Located on the active door panel stile.
- 2-point locking system by Hoppe; Located on the passive
- Latch and deadbolt strike plate; One required; Located on the passive door astragal; Secured with two No. 8 x 1-1/2" screws and one No. 8 x 1" screw.
- Shoot bolt strike plates – active/passive door; Two required; Located at the head and the sill; Secured with two No. 10 x 1-1/2" screws.

Threshold:

- Extruded aluminum threshold; 0.970" high snapped on top of the sill.

Product Identification (Certification Agency Label on Door):

System		
1	Certification Agency	Manufacturer Produced Label
	Manufacturer's Name or Code Name	JELD-WEN Windows & Doors
	Product Name	Premium Atlantic Vinyl (3400) Swinging Patio Door
	Test Standards	ASTM E330-02

Impact Resistance:

Impact Resistant	Requirement
No	Impact protective system required when product is installed in areas where windborne debris protection is required

Installation: The wood wall framing members shall be minimum Spruce-Pine-Fir dimension lumber. The door is secured to the wall framing with minimum No. 10 x 1-1/2" screws. At the head and sill, one fastener is required approximately 7-1/4 inches from each end and two through the strike plates. Along each hinge jamb, the door is secured with the fasteners through the hinges as specified in the hardware section. The fasteners shall be long enough to penetrate a minimum of 1 1/2 inches into the wall framing members. The frame shall be sealed with silicone.

Note: The manufacturer's installation instructions shall be available on the job site during installation. All fasteners shall be corrosion resistant as specified in the International Residential Code (IRC), the International Building Code (IBC), and the Texas Revisions.